Zone GL Sch	State Sch# Alarm	Location/Comment Alarm Group SERVER RM SMOKE	Page GL Page Restore? Equipn	
2	Alarm	2ND FLR ELEV LOBBY	N	100-FIRE
3	Alarm	ELEV LOBBY 1ST FLR	N	100-FIRE
4	Alarm	HALL BY OFFICES	N	100-FIRE
5	Alarm	TOP OF SHAFT SMOKE	N	100-FIRE
6	Alarm	TOP OF SHAFT HEAT	N	100-FIRE
7	Alarm	ELEV EQUIP HEAT	N	100-FIRE
		ELEV EQUIP SMOKE	N	
8	Alarm		N	100-FIRE
9	Alarm	MENS RM BY INTER	N	100-FIRE
10	Alarm	2ND FLR MENS RM	N	100-FIRE
11	Alarm	2ND FLR WOMENS RM	N	100-FIRE
12	Alarm	WORK RM	N	100-FIRE
13	Alarm	HALL BY READY RM	N	100-FIRE
14	Alarm	HRV-1 DUCT DETECTOR	N	7200-FIRE SUPERVISORY ALERT
15	Alarm	AC-3 DUCT DETECTOR	N	7200-FIRE SUPERVISORY ALERT
16	Alarm	AC-2 DUCT DETECTOR	N	7200-FIRE SUPERVISORY ALERT
17	Alarm	AC-1 DUCT DETECTOR	N	7200-FIRE SUPERVISORY ALERT
18	Alarm	MENS RM BY KITCHEN	N	100-FIRE
23	Alarm	STORAGE HEAT	N	100-FIRE
24	Alarm	QUIET RM	N	100-FIRE
25	Alarm	QUIET RM	N	100-FIRE
26	Alarm	MENS LOCKER RM	N	100-FIRE
27	Alarm	WOMENS LOCKER RM	N	100-FIRE
28	Alarm	MENS RR HEAT	N	100-FIRE
29	Alarm	WOMENS RR HEAT	N	100-FIRE

GL Sch	Sch#	Alarm Group	Restore?	Equipment Type
30	Alarm	HALL BY LOCKER RMS	N	100-FIRE
31	Alarm	TECH LAB SMOKE	IN	100-FIRE
			N	
34	Alarm	LARGE EVIDENCE STORAGE FIRE	N	100-FIRE
35	Alarm	EVIDENCE PROCESSING SMOKE	N	100-FIRE
0.0		CONTAIN DRINT FIRE	N	400 FIRE
36	Alarm	CONTAIN PRINT FIRE	N	100-FIRE
37	Alarm	IT WORK ROOM FIRE		100-FIRE
38	Alarm	IT LEAD FIRE	N	100-FIRE
00	71101111	227.0	N	100 1 1112
39	Alarm	IT FIRE	N	100-FIRE
40	Alarm	READY ROOM FIRE	IN	100-FIRE
			N	
41	Alarm	SUPERVISOR FIRE	N	100-FIRE
42	Alarm	SUPERVISOR FIRE		100-FIRE
43	Alarm	SMALL CONFERENCE FIRE	N	100-FIRE
.0	,	3.11	N	.001
44	Alarm	REPORT WRITING FIRE	N	100-FIRE
46	Alarm	RISER ROOM HEAT	IN	100-FIRE
40	Alarm	KO BOOM	N	100 FIRE
48	AldIIII	K9 ROOM	N	100-FIRE
51	Alarm	LOBBY		100-FIRE
52	Alarm	INTERVIEW	N	100-FIRE
			N	
54	Alarm	RECORDS SUPV	N	100-FIRE
57	Alarm	HALL BY KITCHEN		100-FIRE
58	Alarm	KITCHEN HEAT	N	100-FIRE
30	Alami	KHOHENHEAI	N	100-1 IKE
59	Alarm	COMMUNITY TRAINING	N	100-FIRE
60	Alarm	WOMENS RESTRM	IN	100-FIRE
00		NITED WEW DEOV	N	400 FIRE
63	Alarm	INTERVIEW RECV	N	100-FIRE
65	Alarm	RECORDS		100-FIRE
66	Alarm	MAIN HALL	N	100-FIRE
			N	
67	Alarm	FUTURE OFFICE	N	100-FIRE
68	Alarm	BRIEFING		100-FIRE
			N	

Gl	_ Sch	Sch#	Alarm Group	Restore?	Equipment Type
69)	Alarm	ADMIN CLERK		100-FIRE
70)	Alarm	MEDIUM CONFERENCE	N	100-FIRE
				N	
71		Alarm	FUTURE OFFICE	N	100-FIRE
72	<u>!</u>	Alarm	ADMIN ASST	IN	100-FIRE
				N	=:==
73	1	Alarm	LIEUTENANT	N	100-FIRE
74		Alarm	CAPTAIN		100-FIRE
75	:	Alarm	CAPTAIN	N	100-FIRE
70		7 (IQIIII	<i>5</i> , 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1,	N	100 1 1112
76	;	Alarm	CONF RM	N	100-FIRE
77		Alarm	CHIEF	IN	100-FIRE
				N	
78	•	Alarm	ADMIN SUPER	N	100-FIRE
79)	Alarm	HALL BY SECURE FILE		100-FIRE
80	1	Alarm	TACTICAL OPS	N	100-FIRE
00		7 dann	MOTIONE OF G	N	100111112
81		Alarm	COMP FORENSICS	N	100-FIRE
82	<u>.</u>	Alarm	DETECTIVES	IN	100-FIRE
			05045 4444400	N	=:==
83	i	Alarm	CRIME ANALYSIS	N	100-FIRE
84		Alarm	SERGEANT		100-FIRE
85	;	Alarm	LIEUTENANT	N	100-FIRE
				N	
86	i	Alarm	BREAK RM	N	100-FIRE
87	•	Alarm	TESTING	.,	100-FIRE
88		Alarm	QUIET RM	N	100-FIRE
00	•	Alallii	QUETIAM	N	100-1 IIVL
89)	Alarm	TOILET 230	N	100-FIRE
90)	Alarm	HALL BY BREAK RM	IN	100-FIRE
			7,07,170,1	N	=:==
91		Alarm	DISPATCH	N	100-FIRE
92		Alarm	COMM SUPV		100-FIRE
93		Alarm	STREET CRIMES	N	100-FIRE
				N	
94		Alarm	FUTURE SERGEANT	N	100-FIRE
95	;	Alarm	ST CR SERGEANT	14	100-FIRE
				N	

Zone GL Sch	State Sch# Alarm	Location/Comment Alarm Group COMM SPECIALIST	Page GL Page Event Restore? Equipment Type 100-FIRE
97	Alarm	COMM EDUCATION	N 100-FIRE
98	Alarm	LT COMM OFFICE	N 100-FIRE N
99	Alarm	HALL BY COMM	100-FIRE N
202	Alarm	SERVER RM PULL	100-FIRE N
218 219	Alarm	WATER FLOW WATER FLOW TAMPER	100-FIRE N 7200-FIRE SUPERVISORY ALERT
32E110	Alarm	VEHICLE EVIDENCE SMOKE	N 100-FIRE
32E162	Alarm	VEHICLE EVIDENCE CO	N 250-GAS DETECTED N
33E110	Alarm	VEHICLE EVIDENCE FIRE	100-FIRE N
33E162	Alarm	VEHICLE EVIDENCE CO	250-GAS DETECTED N
47E110 47E162	Alarm	SALLY PORT FIRE SALLY PORT CO	100-FIRE N 250-GAS DETECTED
52E110	Alarm	SALLY PORT FIRE	N 100-FIRE
52E162	Alarm	SALLY PORT CO	N 250-GAS DETECTED
E301	Restore	AC LOSS	N 2000-RESTORE N
E301	Trouble	AC LOSS	800-A/C POWER FAILURE N
E302 E302	Restore Trouble	LOW SYSTEM BATTERY	2000-RESTORE N 700-LOW BATTERY
E310	Restore	GROUND FAULT	N 2000-RESTORE
E310	Trouble	GROUND FAULT	N 600-TROUBLE N