



June 10, 2022

The purpose of this addendum is to modify the RFP documents only to the extent indicated herein. All other areas not changed or otherwise modified by other addenda, shall remain in full force and effect. This addendum is hereby made an integral part of the original Project Documents.

1. Question: Could you provide a Zone List?

Answer: The information has been provided as Attachment C.

2. Question: Is there a specific list of equipment needed?

Answer: No. The City would like recommendations based on the scope and requirements of the project areas to be served.

3. Question: What is exactly needed at the Quonset Hut?

Answer: We need the following:

- Two smoke alarms
- Fire/burglary alarm panels
- Garage and main door need to be alarmed
- Manual pull alarm
- Single panel that can have individual employee codes entered

4. Question: What is needed at the 50x50 enclosed fenced in area?

Answer: We need the following:

- Four motion detection cameras that can work together to cover 360-degree area.
- Each camera would be installed on each corner of the fencing.
- Cameras will have built-in infrared ability and can record and provide at least two minutes of footage. That footage should be held by the host company for a minimum of 72 hours.
- Cameras should provide a minimum of four megapixels.
- A wireless connection or battery powered system is preferred.