



CITY OF ALBANY, OREGON
FINANCE DEPARTMENT

ITB# PK-240413, ADA Concrete Improvements – City Parks Phase 1
Invitation to Bid, Addendum 2

May 23, 2024

The purpose of this addendum is to modify the RFQ documents only to the extent indicated herein. All other areas not changed or otherwise modified by other addenda, shall remain in full force and effect. This addendum is hereby made an integral part of the original Project Documents.

1. Question- Is the contractor responsible for construction survey and layout, or will the City perform this?

Answer: The city provided the plans for curb ramps – contractor must make sure through surveys (as needed) that they met the requirements of the engineer's

plan. The pads are 4 inch as described in the bid materials.

2. Question- Bid items A-5, A-7, A-10, and A-12 all have "signage and striping" included in their descriptions. I am not seeing any signing or striping shown on the plans. Can you please clarify where this is located?

Answer: The striping and signage are the appropriate ADA striping and signage for each curb ramp. This should be simple on these ramps. The larger project (later phases) has parking spots etc. which require much more striping/signage etc.

finance.cityofalbany.net

