



CITY OF ALBANY  
Public Works Department

ADDENDUM #1

**WTP-24-01. AM-WTP Generator**

DATE: NOVEMBER 8, 2024

In order to clarify the intent of the Specifications and Drawings, the following provisions are provided and shall be considered part of the contract documents.

**CONSTRUCTION DRAWINGS AND SPECIFICATIONS CLARIFICATION:**

Conduit material within the Mechanical Room and Electrical Room shown on the Construction Drawings may be EMT. Conduit in the lower floors and in the Membrane Room is considered interior to the Plant Area and is subject to the table in **Appendix A, Section 16131, Part 2.1 of the Technical Specifications.**

**BID OPENING DATE AND TIME**

**The bid opening has been rescheduled** for Wednesday, November 13, 2024, at 2:00 p.m.

**ADDITIONAL INFORMATION**

Pre-Bid Attendee List has been uploaded to the City of Albany Website,  
[https://albanyoregon.gov/finance/purchasing/bids?view\\_bid=669](https://albanyoregon.gov/finance/purchasing/bids?view_bid=669).

In order to ensure that all bidders are aware of these provisions, each bidder must sign this addendum below and attach it to the proposal.

**IMPORTANT: Failure to include a signed Addendum could result in the disqualification of your bid.**

\_\_\_\_\_  
Contractor's Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Company Name *(please type or print)*