


Attachment C - Water Avenue Parking Lot, Albany, Oregon



Legend

Sewer - Sewer Laterals

- Public Laterals
- Private Laterals
- Out of Service

Sewer - Sewer Mainlines

- Mainline
- Private Mains

Stormwater - Catch Basins & Inlets

- Publicly Owned

Sewer - Sewer Air Release Valves

- Valves
- Grease Interceptor

Water - Water Main

-

Stormwater - Storm Mainlines

- Unknown Ownership
- Publicly Owned

City of Albany, Water Avenue Parking Lot



Pacific Power, 500 kVA Utility Transformer
Adequate capacity is available per load review
from the Utility Company.

City of Albany, Water Avenue Parking Lot


- Dual Port Level 2 Charger
- Level 3 DC Fast Charger (DCFC)
- Utility wiring
- New Customer owned wiring/conduit
- MS New Customer Metered Service (example)
- New Bollard
- EV Parking Only Sign
- ✚ Future use L2 pull box

Load Requirements:

Qty-1 50 kW 3 phase 208v DCFC

Qty-2 6.2 kW Single phase 208v Level 2 Chargers

Total = 63.4 kW



One-Line Diagram of charging installation

