

333 Broadalbin Street SW, PO Box 490, Albany, Oregon 97321-0144 | PHONE 541-917-7500

ADDENDUM NO. 1

Date: July 2, 2019

To: Interested Bidders

From: Diane M. Murzynski, CPPO, CPPB, Purchasing Coordinator

Re: Sunrise Park Path - PK-19-01 Invitation to Bid (ITB)

The purpose of this Addendum is to clarify, change, and correct the Project Manual and Contract Documents dated June 24, 2019. All other areas not changed or otherwise modified by other addenda shall remain in full force and effect. This Addendum is hereby made an integral part of the original Project Documents. Bidders shall sign below acknowledging they read and understand that this Addendum includes and incorporates the following changes.

ITEM 1 – DRAWINGS

- Sheet L-2
 - a. The City will not supply survey work for staking. Revise Note #1 as follows: Contractor will be provided with AutoCad files for layout purposes. City will supply survey work needed for project staking of paving and site improvements. Contractor to request survey work from city in advance.
- 2. Sheet E-1
 - Pole Base Detail: Luminaire and Pole are furnished and installed by Owner. Conduit, wiring, concrete base and final connections by Contractor.
- Sheet E-2
 - a. Luminaires and Poles are furnished and installed by Owner. Conduit, wiring, concrete base and final connections by Contractor.

End of Addendum #1

Bidder's Signature	Date	
Company Name (Please print)		

finance.cityofalbany.net

