



CITY OF ALBANY
Public Works Department

ADDENDUM #1

ST-19-02, Lochner Road Improvements

In order to clarify the intent of the Specifications and Drawings, the following provisions are provided and shall be considered part of the contract documents.

In order to ensure that all bidders are aware of these provisions, each bidder shall sign this addendum below and attach it to the proposal.

IMPORTANT: Failure to include a signed Addendum could result in the disqualification of your bid.

BID OPENING:

The room for the bid opening has changed. Bids will be opened and publicly read in the **Willamette Room** of City Hall at 2:00p.m.

SCHEDULE OF CONTRACT PRICES:

An updated Schedule of Contract Prices (Pages 6 through 8) is attached.

- Bid Item No. 54, 2-Inch PVC Street Lighting Conduit: bid item quantity changed from 2,575 to 3,165.
- Bid Item No. 86, Directional Drill 2-Inch PVC Street Lighting Conduit: bid item added. Quantity is 250 and unit of measure is Linear Foot.

CONSTRUCTION DRAWINGS:

Replace Sheets 1, 15, 16 and 17 in the Construction Drawings with the new sheets posted separately as “09 Addendum 1 – Construction Drawings.” A summary of changes made to each sheet is provided below.

- Sheet No. 1: Sheet numbers corrected in Sheet Index.
- Sheet No. 15: Changed material of 2-foot radius elbows on 2-inch and 1-inch PVC conduits to PVC instead of fiberglass.
- Sheet No. 16:
 - Changed material of 2-foot radius elbows on 2-inch and 1-inch PVC conduits to PVC instead of fiberglass.
 - Added 2-inch PVC conduit from STA A18+50 to A26+75.
 - Added notes clarifying that the City Contractor shall be responsible for hiring an electrician to install 4-jaw meter base and incidental wiring. Consumers Power, Inc. (CPI) will install meter. City Contractor shall coordinate inspections and meter installation with CPI
 - Changed dimensions of concrete meter pad to 3-foot x 3-foot instead of 1.5-foot x 1.5-foot.

- City Contractor shall coordinate potholing CenturyLink cables between STA A16+30 and A16+78. CenturyLink will relocate cables if they conflict with new streetlight conduit alignment.
- Sheet No. 17:
 - Changed material of 2-foot radius elbows on 2-inch and 1-inch PVC conduits to PVC instead of fiberglass.
 - Added 2-inch PVC conduit from STA A18+50 to A26+75. 2-inch PVC conduit shall be horizontally directionally drilled from STA A24+33 to A26+70.
 - Contractor shall coordinate with CPI to stub 2” and 3” conduits through existing electrical junction wall.

TECHNICAL SPECIFICATIONS SECTION III:

Revisions are shown in bold.

Item No. 56 – Directionally Drill 3-Inch PVC Street Lighting Conduit:

This bid item shall include all work required for directionally drilling 3-inch PVC street lighting conduit at the location shown on the Construction Drawings and as directed by the Engineer. All conduits shall be Schedule 40 PVC and have 500-pound-test pull cords installed for later use by Consumers Power Inc. (CPI). Conduit shall have a **minimum of 48 inches** of cover from finished grade, unless otherwise shown on the Construction Drawings. **Horizontally directionally drilled 2-inch and 3-inch conduits can be installed simultaneously with one bore.** All couplers, bends, risers, caps, and any other required fittings or materials are considered incidental to these bid items. All bends and sweeps shall have a radius of 36 inches and shall be fiberglass unless otherwise called out on the Construction Drawings or directed by the Engineer. All work shall conform to CPI Standard and shall be inspected and approved by CPI prior to backfill.

The Contractor shall coordinate with CPI for inspection of the work east of the Lochner Spur track. Questions regarding CPI's standards and inspections may be directed to John Yastrop with CPI at 541-929-8644.

Payment for this bid item will be on a linear-foot basis and will include all labor, equipment, materials, and incidentals required to complete the work.

Item No. 59 – Install Electrical Meter Pad and Tamper Resistant Meter Box:

See Construction Drawings.

This bid item shall include installation of **concrete meter pad, tamper resistant meter box, and 4-jaw meter base** as shown on the Construction Drawings and as directed by the Engineer. All work shall conform to the CPI Standard. **Coordinating with CPI to schedule any required inspections and to install the new meter are incidental to this bid item. All work shall meet local building and electrical codes. All permits required for installation shall be considered incidental to this bid item.**

Questions regarding CPI's standards and inspections may be directed to John Yastrop with CPI at 541-929-8644.

The Contractor shall submit specifications for tamper resistant meter box for approval by the engineer.

Payment for this bid item will be on a lump-sum basis and will include all equipment, labor, materials, and incidentals required to complete the work.

NEW BID ITEM - Item No. 86 – Directionally Drill 2-Inch PVC Street Lighting Conduit:

This bid item shall include all work required for directionally drilling 2-inch PVC street lighting conduit at the location shown on the Construction Drawings and as directed by the Engineer. All conduits shall be Schedule 40 PVC and have 500-pound-test pull cords installed for later use by Consumers Power Inc. (CPI). Conduit shall have a minimum of 48 inches of cover from finished grade, unless otherwise shown on the Construction Drawings. Horizontally directionally drilled 2-inch and 3-inch conduits can be installed simultaneously with one bore. All couplers, bends, risers, caps, and any other required fittings or materials are considered incidental to these bid items. All bends and sweeps shall have a radius of 24 inches and shall be PVC unless otherwise called out on the Construction Drawings or directed by the Engineer. All work shall conform to CPI Standard and shall be inspected and approved by CPI prior to backfill.

The Contractor shall coordinate with CPI for inspection of the work east of the Lochner Spur track. Questions regarding CPI's standards and inspections may be directed to John Yastrop with CPI at 541-929-8644.

Payment for this bid item will be on a linear-foot basis and will include all labor, equipment, materials, and incidentals required to complete the work.

Contractor's Signature

Date

Company Name *(please type or print)*

SCHEDULE OF CONTRACT PRICES

ITEM NO.	BID ITEMS	APPROX. QUANTITY	UNIT OF MEASURE	UNIT PRICE DOLLARS/CTS	TOTAL AMT. DOLLARS/CTS
1	Mobilization	1	Lump Sum		
2	Temporary Traffic Control	1	Lump Sum		
3	Erosion Prevention and Sediment Control	1	Lump Sum		
4	Coordinate with Railroads at Marion Street Crossing	1	Lump Sum		
5	Coordinate with Railroads at Lochner Road Crossing	1	Lump Sum		
6	Unclassified Excavation	14,000	Cubic Yard		
7	Overexcavation and Foundation Stabilization	1,850	Cubic Yard		
8	Subgrade Geotextile Fabric	9,300	Square Yard		
9	Crushed Aggregate Base	9,000	Ton		
10	3/8-Inch Warm Mix Asphalt Concrete Wearing Course	1,150	Ton		
11	1/2-Inch Warm Mix Asphalt Concrete Base Course	3,500	Ton		
12	Transition Paving	60	Square Yard		
13	Emulsified Asphalt Tack Coat	19,350	Square Yard		
14	Standard Curb and Gutter	4,820	Linear Foot		
15	4-Inch PCC Sidewalk	2,000	Square Yard		
16	8-Inch PCC Driveway Approach	200	Square Yard		
17	Truncated Domes	124	Square Foot		
18	Install ODOT Pedestrian Handrail	40	Linear Foot		
19	Remove Railroad Guardrail and Posts	1	Lump Sum		
20	8-Inch Ductile Iron Storm Drain	460	Linear Foot		
21	10-Inch Ductile Iron Storm Drain	40	Linear Foot		
22	10-Inch Storm Drain	260	Linear Foot		
23	12-Inch Storm Drain	375	Linear Foot		
24	15-Inch Storm Drain	230	Linear Foot		
25	18-Inch Storm Drain	735	Linear Foot		
26	30-Inch Storm Drain	955	Linear Foot		
27	36-Inch Storm Drain	20	Linear Foot		
28	Open Trench 24-Inch Steel Casing with 12-Inch PVC Carrier Pipe	120	Linear Foot		
29	12-Inch Culvert	50	Linear Foot		
30	Shallow Precast Manhole	6	Each		
31	60-Inch Precast Manhole	5	Each		
32	72-Inch Precast Manhole	1	Each		

ITEM NO.	BID ITEMS	APPROX. QUANTITY	UNIT OF MEASURE	UNIT PRICE DOLLARS/CTS	TOTAL AMT. DOLLARS/CTS
33	24-Inch Beehive Overflow Inlet	1	Each		
34	Connect to Existing Manhole	1	Lump Sum		
35	Standard Curb Inlet	4	Each		
36	Standard Catch Basin	41	Each		
37	ODOT Type D Inlet	2	Each		
38	Adjust Fixtures to Grade	1	Lump Sum		
39	Remove Existing Storm Drain	320	Linear Foot		
40	Abandon Existing Storm Drain	1	Lump Sum		
41	Remove Existing Storm Drain Inlet	2	Each		
42	Construct Stormwater Planter 1	1	Lump Sum		
43	Construct Stormwater Planter 2	1	Lump Sum		
44	Construct Stormwater Planter 3	1	Lump Sum		
45	Construct Stormwater Planter 4	1	Lump Sum		
46	Construct Stormwater Planter 5	1	Lump Sum		
47	Regrade Existing Ditch	55	Linear Foot		
48	Plant and Establish Stormwater Quality Plantings	1	Lump Sum		
49	Plant and Establish Street Trees	1	Lump Sum		
50	Plant and Establish Private Trees and Shrubs	1	Lump Sum		
51	Landscape Restoration	1	Lump Sum		
52	Relocate Existing Mailbox	3	Each		
53	1-Inch PVC Street Lighting Conduit	50	Linear Foot		
54	2-Inch PVC Street Lighting Conduit	3,165	Linear Foot		
55	3-Inch PVC Street Lighting Conduit	600	Linear Foot		
56	Directional Drill 3-Inch PVC Street Lighting Conduit	245	Linear Foot		
57	Install Franchise Utility Power Junction Box	16	Each		
58	Install Transformer Pad	1	Lump Sum		
59	Install Electrical Meter Pad and Tamper Resistant Meter Box	1	Lump Sum		
60	Open Trench 6-Inch Steel Casing	100	Linear Foot		
61	4-Inch Yellow Profiled Thermoplastic Stripe	4,800	Linear Foot		
62	4-Inch Yellow Non-Profiled Thermoplastic Stripe	140	Linear Foot		
63	4-Inch White Non-Profiled Thermoplastic Stripe	330	Linear Foot		
64	8-Inch White Non-Profiled Thermoplastic Stripe	5,050	Linear Foot		
65	12-Inch White Non-Profiled Thermoplastic Stripe	475	Linear Foot		

ITEM NO.	BID ITEMS	APPROX. QUANTITY	UNIT OF MEASURE	UNIT PRICE DOLLARS/CTS	TOTAL AMT. DOLLARS/CTS
66	Thermoplastic Railroad Crossing Legend	2	Each		
67	Thermoplastic Bicycle Lane Legend	7	Each		
68	Thermoplastic Bicycle Lane Left Arrow Only	2	Each		
69	Raised Reflectorized Pavement Marker	65	Each		
70	Install New Street Signs	20	Each		
71	Relocate Existing Street Signs	8	Each		
72	Remove Existing Street Signs	5	Each		
73	10-Inch Asphalt Trench Patch	100	Square Yard		
74	4-Inch Asphalt Trench Patch	50	Square Yard		
75	6-Inch Private Concrete Driveway	25	Square Yard		
76	Pothole Existing 12-Inch Asbestos Cement Water Line	1	Lump Sum		
77	Pothole Existing 16-Inch Ductile Iron Water Line	1	Lump Sum		
78	12-Inch Ductile Iron Water Line	210	Linear Foot		
79	12-Inch Butterfly Valve	2	Each		
80	STA B4+02.13 Connect to Existing Water Line	1	Lump Sum		
81	12-Inch X 12-Inch Connection Assembly	1	Lump Sum		
82	Combination Air/Vacuum Release Valve	1	Each		
83	Abandon Temporary Water Line Connection	1	Lump Sum		
84	Remove Existing Asbestos Cement Water Line	140	Linear Foot		
85	Relocate Private Irrigation Infrastructure	1	Lump Sum		
86	Directional Drill 2-Inch PVC Street Lighting Conduit	250	Linear Foot		
SUM OF EXTENDED TOTALS					

NOTE: Subject to change if addition or extensions are in error.

Bidder's Signature	Company Name <i>(please print)</i>	Date
Bidder's Name <i>(please print)</i>	Mailing Address <i>(please print)</i>	CCB License Number
Bidder's Title <i>(please print)</i>	City, State Zip	Federal Tax ID Number
Telephone No.: _____	Fax No.: _____	Email: _____