



CITY OF ALBANY  
Public Works Department

ADDENDUM #1

**WL-20-03, Gibson Hill Road and Park Terrace Water Line**

In order to clarify the intent of the Specifications and Drawings, the following provisions are provided and shall be considered part of the contract documents.

In order to ensure that all bidders are aware of these provisions, each bidder shall sign this addendum below and attach it to the proposal.

**IMPORTANT: Failure to include a signed Addendum could result in the disqualification of your bid.**

**Existing Concrete Thrust Restraint**

The existing water mains were built with a combination of internal restraint (locking gaskets and retainer glands) and concrete thrust restraint. The Contractor shall assume that any existing concrete thrust restraint will not interfere with the work. Any unforeseen extra work associated with encountering existing concrete thrust restraints during construction will be paid under a change order.

\_\_\_\_\_  
Contractor's Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Company Name *(please type or print)*